

Results of Aquifer Test Analysis

for the

Center Point Taylor

Well No. 3 - Middle Trinity Aquifer

(HGCD Permit No. P0037; HGCD Well No. 1342)

for

Aqua Texas, Inc.

512 Rodriguez Street

Kerrville, TX 78028

WRGS Project No. 006-008-09

March 17, 2010



Wet Rock Groundwater Services, L.L.C.

Groundwater Specialists

TBPG Firm No: 50038


P.O. Box 163144

Austin, Texas 78716

Ph: 512-773-3226 Fax: 512-879-6809

www.wetrockgs.com

The seal appearing on this document was authorized on March 17, 2010 by:



Kaveh Khorzad, P.G.
License No. 1126

Wet Rock Groundwater Services, LLC
TBPG Firm Registration No. 50038



(This Page Left Blank Intentionally)





Wet Rock Groundwater Services, L.L.C.

Groundwater Specialists

TBPG Firm No: 50038

P.O. Box 163144

Austin, Texas 78716

Ph: 512-773-3226 Fax: 512-879-6809

www.wetrockgs.com

Aqua Texas, Inc.

Center Point Taylor

Well No. 3 - Middle Trinity Aquifer

HGCD Permit No. P0037; HGCD Well No. 1342

Contents


Attachment 1:	Well Location Map
Attachment 2:	Geological Cross Section
Attachment 3:	U.S. Geological Survey Topographic Map
Attachment 4:	Log Plot: Center Point Taylor Well No. 3
Attachment 5:	State of Texas Well Report
Attachment 6:	Table 1 - Well Construction Summary Table 2 - Aquifer Testing Summary Table 3 - Summary of Aquifer Testing Analyses
Attachment 7:	Aquifer Test Drawdown and Temperature Curves
Attachment 8:	Aquifer Test Analyses
Attachment 9:	Aquifer Test Data



Attachment 1

Well Location Map






SCALE: 1 in = 6 miles

DRAWN BY: CAM DATE: 3/10

REVISED BY: DATE:

PROJECTION: UTM NAD 83 Zone 14



Aqua Texas, Inc.
Kerr County, Texas

Well Location Map



Wet Rock Groundwater Services, L.L.C.
Groundwater Specialists
TBPG Firm No: 50038
P.O. Box 163144 Austin, Texas 78716
PH: 512-773-3226 FAX: 512-879-6809
www.wetrockgs.com




Attachment 2

Geological Cross Section



A

A'



Geological Cross Section A-A'

DRAWN BY: CAM **DATE:** 3/10
REVISED BY: **DATE:**
PROJECTION: UTM NAD 83 Zone 14

Aqua Texas, Inc.
 Kerr County, Texas




Wet Rock Groundwater Services, L.L.C.
 Groundwater Specialists
 TBPG Firm No: 50038
 P.O. Box 163144 Austin, Texas 78716
 PH: 512-773-3226 FAX: 512-879-6809
 www.wetrockgs.com

Attachment 3

U.S. Geological Survey Topographic Map





SCALE: 1 in = 1,000 ft

Center Point Taylor No. 3 Topo Map

DRAWN BY: CAM DATE: 3/10

REVISED BY: DATE:

PROJECTION: UTM NAD 83 Zone 14

Aqua Texas, Inc.
Center Point Taylor
Well No. 3
Kerr County, Texas



Wet Rock Groundwater Services, L.L.C.
Groundwater Specialists
 TBPG Firm No: 50038
 P.O. Box 163144 Austin, Texas 78716
 PH: 512-773-3226 FAX: 512-879-6809
 www.wetrockgs.com

Attachment 4

Log Plot: Center Point Taylor Well No. 3





Wet Rock Groundwater Services, LLC
Groundwater Specialists

P.O. Box 163144 Austin, TX 78716
 Ph: 512.799.5875 Fax: 512.879.6809
 www.wetrockgs.com

Center Point Taylor No. 3 (Middle Trinity)

Client: **Aqua Texas, Inc.**
 Date Started: **2/13/2007**
 Date Completed: **3/30/2007**
 Drilled By: **Davenport Drilling & Pump Service**
 Drilling Type: **Air Rotary**

Location: **Kerr County, TX**
 Elevation: **1,514 ft MSL**
 Total Depth: **434 ft**
 Latitude: **29.942083 (WGS84)**
 Longitude: **-99.045556 (WGS84)**

	-150	SP mV	450

	0	SPR ohm	100



	0	Gamma Ray API	200

10	R8 ohm-m	1000		

10	R16 ohm-m	1000		

10	R32 ohm-m	1000		

10	R64 ohm-m	1000		



Attachment 5

State of Texas Well Report



Please use black ink.

Trend original copy by certified mail to: TNRCC, P.O. Box 13087, Austin, TX 78711-3087

Texas Water Well Drillers Advisory Council
P.O. Box 13087
Austin, TX 78711-3087
512-239-0530

State of Texas WELL REPORT

1) OWNER AQUA TEXAS, INC. ADDRESS 1421 WELLS BRANCH PARKWAY PFLUGERVILLE TX 78660
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County KERR CENTERPOINT 3 TX GRID # N 29° 56' 31.5"
(Street, RFD or other) (City) (State) (Zip) W099° 02' 44.0"

3) TYPE OF WORK (Check):
 New Well Deepening
 Reconditioning Plugging

4) PROPOSED USE (Check): Monitor Environmental Soil Boding Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

5) DRILLING METHOD (Check): Driven
 Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

6) WELL LOG:
Date Drilling:
Started 02-13 20 07
Completed 3-30 20 07

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
<u>12 3/4</u>	<u>SURFACE</u>	<u>440</u>

From (ft.)	To (ft.)	Description and color of formation material
<u>0</u>	<u>20</u>	<u>TOP SOIL & CLAY</u>
<u>20</u>	<u>40</u>	<u>GRAVEL & CLAY</u>
<u>40</u>	<u>100</u>	<u>UPPER GLENROSE</u>
<u>100</u>	<u>320</u>	<u>LOWER GLENROSE</u>
<u>320</u>	<u>370</u>	<u>BEXAR SHALE</u>
<u>370</u>	<u>440</u>	<u>COW CREEK</u>
<u>440</u>	<u>450</u>	<u>PINE ISLAND</u>

8) Borehole Completion (Check): Open Hole Straight Wall
 Underreamed Gravel Packed Other SCREEN
If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casing Screen
			From	To	
<u>8</u>	<u>N</u>	<u>STEEL</u>	<u>0</u>	<u>384</u>	<u>322</u>
<u>8</u>	<u>N</u>	<u>SCREEN</u>	<u>384</u>	<u>424</u>	<u>322</u>
<u>8</u>	<u>N</u>	<u>STEEL BLANK</u>	<u>424</u>	<u>434</u>	<u>322</u>

9) CEMENTING DATA [Rule 338.44(1)]
Cemented from 0 ft. to 370 ft. No. of sacks used 162
ft. to _____ ft. No. of sacks used _____
Method used PRESSURE CEMENTED
Cemented by SCHLUMBERGER
Distance to septic system field lines or other concentrated contamination 150 FT
Method of verification of above distance MEASURED

13) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other N/A
Depth to pump bowls, cylinder, jet, etc., _____ ft.

14) WELL TESTS:
Type Test: Pump Bailor Jetted Estimated
Yield: 165 gpm with 102 ft. drawdown after 36 hrs.

15) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? GOOD Depth of strata 60'
Was a chemical analysis made? Yes No

10) SURFACE COMPLETION
 Specified Surface Slab Installed [Rule 338.44(2)(A)]
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
 Pitless Adapter Used [Rule 338.44(3)(b)]
 Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL
Static Level 201 ft. below land surface Date 3-30-07
Artesian flow _____ gpm Date _____

12) PACKERS:
Type _____ Depth N/A

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME DAVENPORT DRILLING & PUMP SERVICE WELL DRILLER'S LICENSE NO. 2869-WPKT
(Type or print)
ADDRESS 11844 BANDERA RD. PMB 711 MELOTES TEXAS 78023
(Street or RFD) (City) (State) (Zip)
(Signed) [Signature] (Signed) Jacob DeLeon
(Licensed Well Driller) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

Attachment 6

Table 1 - Well Construction Summary

Table 2 - Aquifer Testing Summary

Table 3 - Summary of Aquifer Testing Analyses



Table 1 - Well Construction Summary

<u>Well</u>	<u>Hole Diameter (inches)</u>	<u>From (ft)</u>	<u>To (ft)</u>	<u>Casing Type</u>	<u>Casing Diameter (inches)</u>	<u>From (ft)</u>	<u>To (ft)</u>
Center Point Taylor No. 3	12.75	0	440	Steel Casing	8	0	384
				SS Screen	8	384	424
				Steel Blank	8	424	434

Table 2 - Aquifer Testing Summary

<u>Well</u>	<u>Static Water Level (ft MSL)</u>	<u>Q (gpm)</u>	<u>Drawdown (ft)</u>	<u>SC (gpm/ft)</u>	<u>Pumping Duration (minutes)</u>	<u>Δt (°F)</u>	<u>T_{R90} (minutes)</u>
Center Point Taylor No. 3	1,312.9	145	102.8	1.41	2,656	-0.28	1,900

Notes: Q = discharge; SC = specific capacity; r = distance from pumping well; Δt = change in temperature; T_{R90} = Time pumping well Recovered 90%

Table 3 - Summary of Aquifer Testing Analyses

<u>Analysis</u>	<u>b (ft)</u>	<u>T (ft²/day)</u>	<u>K</u>
Theis	56	120	2.14
Theis Recovery	56	118	2.11
Average:	56	119	2.13

Notes: b = aquifer thickness; r = distance from pumping well; T = transmissivity; S = storativity; K = hydraulic conductivity




Attachment 7

Aquifer Test Drawdown and Temperature Curves



Center Point Taylor No. 3 Aquifer Test - 3/8/2007



Attachment 8

Aquifer Test Analyses





Wet Rock Groundwater Services, LLC
Groundwater Specialists
 P.O. Box 163144 Austin, Texas 78716
 Ph: 512.773.3226 Fax: 512.879.6809
 www.wetrockgs.com

Pumping Test Analysis Report

Project: Headwaters Aquifer Properties

Number: 006-008-09

Client: Headwaters GCD

Location: Kerr County, TX

Pumping Test: Center Point Taylor No. 3

Pumping Well: Center Point Taylor No. 3

Test Conducted by:

Test Date: 3/8/2007

Analysis Performed by: Cassidy Miller


Theis

Analysis Date: 3/5/2010

Aquifer Thickness: 56.00 ft

Discharge: variable, average rate 145.19 [U.S. gal/min]

Equivalent Time



Calculation after Theis

Observation Well	Transmissivity [ft ² /d]	Hydraulic Conductivity [ft/d]	Storage coefficient	Radial Distance to PW [ft]
Center Point Taylor No. 3	1.20×10^2	2.14×10^0		



Wet Rock Groundwater Services, LLC
Groundwater Specialists
 P.O. Box 163144 Austin, Texas 78716
 Ph: 512.773.3226 Fax: 512.879.6809
 www.wetrockgs.com

Pumping Test Analysis Report

Project: Headwaters Aquifer Properties

Number: 006-008-09

Client: Headwaters GCD

Location: Kerr County, TX

Pumping Test: Center Point Taylor No. 3

Pumping Well: Center Point Taylor No. 3

Test Conducted by:

Test Date: 3/8/2007


Analysis Performed by: Cassidy Miller

Theis Recovery

Analysis Date: 3/5/2010

Aquifer Thickness: 56.00 ft

Discharge: variable, average rate 145.19 [U.S. gal/min]



Calculation after Theis & Jacob

Observation Well	Transmissivity [ft ² /d]	Hydraulic Conductivity [ft/d]	Radial Distance to PW [ft]
Center Point Taylor No. 3	1.18×10^2	2.11×10^0	

Attachment 9

Aquifer Test Data



Center Point Taylor No. 3 Pump Test Summary (3-8-2007)

Date and Time	Time Since Pump Start (min)	Time Since Pump Stop (min)	Temperature (F)	Water Level (ft bgs)	Water Level (ft MSL)	Drawdown (ft)	Pump Rate (gpm)	Specific Capacity (gpm/ft)	Comments
3/8/2007 18:23	0		71.61	201.09	1,312.91	0.00			Pumping Start
3/8/2007 18:24	1		71.60	206.88	1,307.12	5.80	178	30.71	
3/8/2007 18:25	2		71.63	210.91	1,303.09	9.83			
3/8/2007 18:26	3		71.71	213.28	1,300.72	12.19	178	14.60	
3/8/2007 18:27	4		71.75	215.06	1,298.94	13.97			
3/8/2007 18:28	5		71.76	216.52	1,297.48	15.43	178	11.53	
3/8/2007 18:29	6		71.76	217.65	1,296.35	16.57			
3/8/2007 18:30	7		71.76	218.76	1,295.24	17.68			
3/8/2007 18:31	8		71.74	219.94	1,294.06	18.85			
3/8/2007 18:32	9		71.75	220.62	1,293.38	19.54			
3/8/2007 18:33	10		71.75	221.63	1,292.37	20.55	178	8.66	
3/8/2007 18:34	11		71.74	222.35	1,291.65	21.26			
3/8/2007 18:35	12		71.67	222.92	1,291.08	21.83			
3/8/2007 18:36	13		71.65	223.48	1,290.52	22.39			
3/8/2007 18:37	14		71.63	224.17	1,289.83	23.08			
3/8/2007 18:38	15		71.62	224.72	1,289.28	23.64	165	6.98	
3/8/2007 18:43	20		71.61	227.56	1,286.45	26.47	162	6.12	
3/8/2007 18:53	30		71.58	232.32	1,281.68	31.23			
3/8/2007 19:08	45		71.53	237.79	1,276.21	36.71			
3/8/2007 19:23	60		71.53	241.94	1,272.06	40.85			
3/8/2007 19:38	75		71.51	245.55	1,268.46	44.46			
3/8/2007 19:53	90		71.51	248.53	1,265.47	47.44			
3/8/2007 20:08	105		71.49	251.22	1,262.78	50.13			
3/8/2007 20:23	120		71.48	253.45	1,260.55	52.36			
3/8/2007 21:23	180		71.46	259.99	1,254.01	58.90			
3/8/2007 22:23	240		71.44	263.69	1,250.31	62.60			
3/8/2007 23:23	300		71.46	266.82	1,247.18	65.73			
3/9/2007 0:23	360		71.45	269.42	1,244.58	68.33			
3/9/2007 1:23	420		71.45	271.50	1,242.50	70.41			
3/9/2007 2:23	480		71.45	273.41	1,240.59	72.32			
3/9/2007 3:23	540		71.45	274.93	1,239.07	73.85			

Note: bgs = below ground surface

MSL = Mean Sea Level

Center Point Taylor No. 3 Pump Test Summary (3-8-2007)

Date and Time	Time Since Pump Start (min)	Time Since Pump Stop (min)	Temperature (F)	Water Level (ft bgs)	Water Level (ft MSL)	Drawdown (ft)	Pump Rate (gpm)	Specific Capacity (gpm/ft)	Comments
3/9/2007 4:23	600		71.44	276.01	1,237.99	74.92			
3/9/2007 5:23	660		71.44	277.21	1,236.79	76.12			
3/9/2007 6:23	720		71.44	278.24	1,235.76	77.15			
3/9/2007 7:23	780		71.44	279.07	1,234.93	77.99			
3/9/2007 8:23	840		71.44	279.67	1,234.33	78.58			
3/9/2007 9:23	900		71.43	280.28	1,233.72	79.20			
3/9/2007 10:23	960		71.43	280.16	1,233.84	79.08			
3/9/2007 11:23	1,020		71.43	290.25	1,223.75	89.17			
3/9/2007 12:23	1,080		71.41	293.12	1,220.88	92.04			
3/9/2007 13:23	1,140		71.38	294.82	1,219.18	93.73			
3/9/2007 14:23	1,200		71.38	296.05	1,217.95	94.97			
3/9/2007 15:23	1,260		71.37	297.07	1,216.93	95.98			
3/9/2007 16:23	1,320		71.37	298.07	1,215.93	96.98			
3/9/2007 17:23	1,380		71.36	298.68	1,215.32	97.59			
3/9/2007 18:23	1,440		71.36	299.13	1,214.87	98.04			
3/9/2007 19:23	1,500		71.36	299.67	1,214.33	98.58			
3/9/2007 20:23	1,560		71.36	300.29	1,213.71	99.21			
3/9/2007 21:23	1,620		71.35	300.92	1,213.08	99.83			
3/9/2007 22:23	1,680		71.35	301.58	1,212.42	100.49			
3/9/2007 23:23	1,740		71.35	302.22	1,211.78	101.13			
3/10/2007 0:23	1,800		71.34	302.73	1,211.27	101.64			
3/10/2007 1:23	1,860		71.34	303.11	1,210.89	102.02			
3/10/2007 2:23	1,920		71.34	303.99	1,210.01	102.90			
3/10/2007 3:23	1,980		71.34	304.56	1,209.44	103.47			
3/10/2007 4:23	2,040		71.34	304.58	1,209.42	103.49			
3/10/2007 5:23	2,100		71.35	304.64	1,209.36	103.55			
3/10/2007 6:23	2,160		71.34	304.69	1,209.31	103.60			
3/10/2007 7:23	2,220		71.34	304.54	1,209.46	103.46			
3/10/2007 8:23	2,280		71.34	304.54	1,209.46	103.45			
3/10/2007 9:23	2,340		71.35	304.55	1,209.45	103.46			
3/10/2007 10:23	2,400		71.35	304.36	1,209.64	103.27			

Note: bgs = below ground surface

MSL = Mean Sea Level

Center Point Taylor No. 3 Pump Test Summary (3-8-2007)

Date and Time	Time Since Pump Start (min)	Time Since Pump Stop (min)	Temperature (F)	Water Level (ft bgs)	Water Level (ft MSL)	Drawdown (ft)	Pump Rate (gpm)	Specific Capacity (gpm/ft)	Comments
3/10/2007 11:23	2,460		71.33	304.23	1,209.77	103.14			
3/10/2007 12:23	2,520		71.34	304.10	1,209.90	103.01			
3/10/2007 13:23	2,580		71.35	303.93	1,210.08	102.84			
3/10/2007 14:23	2,640		71.34	303.80	1,210.20	102.71			
3/10/2007 14:39	2,656	0	71.34	303.86	1,210.15	102.77	145	1.41	Start Recovery
3/10/2007 14:40	2,657	1	71.35	301.98	1,212.02	100.89			
3/10/2007 14:41	2,658	2	71.38	299.38	1,214.63	98.29			
3/10/2007 14:42	2,659	3	71.38	297.63	1,216.37	96.55			
3/10/2007 14:43	2,660	4	71.40	296.16	1,217.84	95.07			
3/10/2007 14:44	2,661	5	71.41	294.88	1,219.12	93.79			
3/10/2007 14:45	2,662	6	71.42	293.74	1,220.26	92.65			
3/10/2007 14:46	2,663	7	71.42	292.70	1,221.30	91.61			
3/10/2007 14:47	2,664	8	71.42	291.75	1,222.25	90.66			
3/10/2007 14:48	2,665	9	71.42	290.81	1,223.19	89.72			
3/10/2007 14:49	2,666	10	71.41	289.90	1,224.10	88.81			
3/10/2007 14:50	2,667	11	71.41	289.13	1,224.87	88.04			
3/10/2007 14:51	2,668	12	71.41	288.36	1,225.64	87.27			
3/10/2007 14:52	2,669	13	71.40	287.67	1,226.33	86.58			
3/10/2007 14:53	2,670	14	71.40	287.01	1,226.99	85.93			
3/10/2007 14:54	2,671	15	71.40	286.30	1,227.70	85.22			
3/10/2007 15:09	2,686	30	71.47	278.36	1,235.64	77.27			
3/10/2007 15:24	2,701	45	71.59	272.40	1,241.60	71.31			
3/10/2007 15:39	2,716	60	71.50	267.68	1,246.32	66.59			
3/10/2007 15:54	2,731	75	71.45	263.76	1,250.24	62.67			
3/10/2007 16:09	2,746	90	71.39	260.33	1,253.67	59.24			
3/10/2007 16:24	2,761	105	71.32	257.34	1,256.66	56.26			
3/10/2007 16:39	2,776	120	71.29	254.77	1,259.23	53.68			
3/10/2007 17:39	2,836	180	71.19	246.66	1,267.34	45.57			
3/10/2007 18:39	2,896	240	71.13	241.05	1,272.95	39.96			
3/10/2007 19:39	2,956	300	71.09	236.76	1,277.24	35.67			
3/10/2007 20:39	3,016	360	71.07	233.48	1,280.52	32.40			

Note: bgs = below ground surface

MSL = Mean Sea Level

Center Point Taylor No. 3 Pump Test Summary (3-8-2007)

Date and Time	Time Since Pump Start (min)	Time Since Pump Stop (min)	Temperature (F)	Water Level (ft bgs)	Water Level (ft MSL)	Drawdown (ft)	Pump Rate (gpm)	Specific Capacity (gpm/ft)	Comments
3/10/2007 21:39	3,076	420	71.07	230.79	1,283.21	29.70			
3/10/2007 22:39	3,136	480	71.05	228.61	1,285.39	27.52			
3/10/2007 23:39	3,196	540	71.07	226.77	1,287.23	25.68			
3/11/2007 0:39	3,256	600	71.16	225.18	1,288.83	24.09			
3/11/2007 1:39	3,316	660	71.12	223.87	1,290.13	22.78			
3/11/2007 3:39	3,376	720	71.09	222.54	1,291.46	21.45			
3/11/2007 4:39	3,436	780	71.07	221.46	1,292.54	20.37			
3/11/2007 5:39	3,496	840	71.06	220.39	1,293.61	19.30			
3/11/2007 6:39	3,556	900	71.12	219.49	1,294.51	18.40			
3/11/2007 7:39	3,616	960	71.43	218.74	1,295.26	17.65			
3/11/2007 8:39	3,676	1,020	71.45	217.97	1,296.03	16.88			
3/11/2007 9:39	3,736	1,080	71.45	217.30	1,296.70	16.21			
3/11/2007 10:39	3,796	1,140	71.43	216.62	1,297.38	15.53			
3/11/2007 11:39	3,856	1,200	71.42	216.02	1,297.98	14.94			
3/11/2007 12:39	3,916	1,260	71.42	215.51	1,298.49	14.42			
3/11/2007 13:39	3,976	1,320	71.41	215.06	1,298.94	13.97			
3/11/2007 14:39	4,036	1,380	71.38	214.61	1,299.39	13.52			
3/11/2007 15:39	4,096	1,440	71.29	214.18	1,299.82	13.09			
3/11/2007 16:39	4,156	1,500	71.35	213.79	1,300.22	12.70			
3/11/2007 17:39	4,216	1,560	71.37	213.41	1,300.59	12.32			
3/11/2007 18:39	4,276	1,620	71.33	213.00	1,301.00	11.91			
3/11/2007 19:39	4,336	1,680	71.34	212.66	1,301.34	11.58			
3/11/2007 20:39	4,396	1,740	71.32	212.32	1,301.68	11.23			
3/11/2007 21:39	4,456	1,800	71.30	212.00	1,302.00	10.91			
3/11/2007 22:39	4,516	1,860	71.26	211.61	1,302.40	10.52			
3/11/2007 23:39	4,576	1,920	71.25	211.33	1,302.67	10.24			
3/12/2007 0:39	4,636	1,980	71.21	211.05	1,302.95	9.96			
3/12/2007 1:39	4,696	2,040	71.14	210.74	1,303.26	9.65			
3/12/2007 2:39	4,756	2,100	71.16	210.55	1,303.45	9.47			
3/12/2007 3:39	4,816	2,160	71.18	210.28	1,303.72	9.19			
3/12/2007 4:39	4,876	2,220	71.31	210.11	1,303.89	9.02			

Note: bgs = below ground surface

MSL = Mean Sea Level

Center Point Taylor No. 3 Pump Test Summary (3-8-2007)

Date and Time	Time Since Pump Start (min)	Time Since Pump Stop (min)	Temperature (F)	Water Level (ft bgs)	Water Level (ft MSL)	Drawdown (ft)	Pump Rate (gpm)	Specific Capacity (gpm/ft)	Comments
3/12/2007 5:39	4,936	2,280	71.29	209.85	1,304.16	8.76			
3/12/2007 6:39	4,996	2,340	71.25	209.65	1,304.35	8.56			
3/12/2007 7:39	5,056	2,400	71.21	209.39	1,304.62	8.30			
3/12/2007 8:39	5,116	2,460	71.19	209.21	1,304.79	8.12			
3/12/2007 9:39	5,176	2,520	71.16	208.96	1,305.05	7.87			
3/12/2007 10:39	5,236	2,580	71.15	208.73	1,305.27	7.64			
3/12/2007 11:00	5,257	2,601	71.14	208.63	1,305.38	7.54			

Note: bgs = below ground surface
MSL = Mean Sea Level